



PRODUCT TESTING SERVICE

100 Clemson Research Blvd. Anderson, SC 29625 Tel (864) 646-TILE Fax (864) 646-2821
TCNA TEST REPORT NUMBER: TCNA-463-07 PAGE: 1 OF 1

TEST REQUESTED BY:

Creative Mosaic Designs
Attn: Jack O'Farrell
1121 Holland Dr., Unit 6
Boca Raton, FL 33487

TEST SUBJECT MATERIAL:

Identified by client as: Mosaic Tiles

TEST DATE:

12/12/07-1/7/08

TEST PROCEDURE:


ASTM C1026: "Standard Test Method for Measuring the Resistance of Ceramic Tile to Freeze-Thaw Cycling"

-Ten specimens were tested.

-The specimens were subjected to fifteen cycles of freeze-thaw consisting of freezing the tiles at 0°F for eight hours then thawing the tiles in water at 74°F.

TEST RESULTS:

All ten (10) specimens showed **no** visible evidence of freeze-thaw damage after completing fifteen (15) cycles of freeze-thaw.


Katelyn Simpson
Laboratory Engineer

1/8/08
Date